

June 18, 2021

Addendum No. 2:

Project: <u>PSFA PROJECT NO: P19-009</u> – Mesa Middle School Renovations and Addition – Roswell Independent School District and PSFA

To All Bidders:

The following items shall be incorporated into the above referenced project. These items shall modify or clarify the published project construction documents as stated herein. The Contractor shall acknowledge receipt of this addendum on the Proposal Form.

Owner:

Roswell Independent School District 300 North Kentucky Avenue, Roswell, NM 88203 Phone (575) 637-3319 Fax (575) 627-2630 Mr. Jeremy Sánchez, Project Manager JeSanchez@risd.k12.nm.us

Architect:

Huitt-Zollars Inc.
6501 Americas Parkway NE Suite 830
Albuquerque, NM 87110
Phone (505) 883-8114
Fax (505)-883-5022
Mr. Joseph Gallegos, AIA, LEED AP BD+C jgallegos@huitt-zollars.com

QUESTIONS

- 1. Key note J & K on Sheet C500 call out for 18" CMP pipe and end sections. Plans call out for RCP. Can you confirm the pipe material needed?
 - a. The contractor has the option for this culvert and end sections similar to the NMDOT 2019 Specifications and the material can be CMP, RCP, or Corrugated HDPE.

APPROVED SUBSTITUTIONS

- Section 07 4213.13 Formed Metal Wall Panels Pac-Clad; Exposed Fastener &
 Concealed Fastener Wall Panels; Elk Grove Village, IL 60007; Southwest Glass &
 Glazing, 505-345-5565.
- 2. <u>Section 08 4113 Aluminum Framed Entrances and Storefronts Tubelite; T14000, Medium Stile Doors; Southwest Glass & Glazing, 505-345-5565.</u>



SPECIFICATIONS

MODIFY - Section 06 1000 SHEATHING Section 2.2 as shown below:

- 2.2 EXTERIOR WALL SHEATHING
- A. Glass-Mat Gypsum Sheathing: ASTM C 1177/1177M.
 - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - a. G-P Gypsum Corporation.
 - b. Or approved equal.
 - 2. Basis of Design: DensGlass Gold®
 - 3. Type and Thickness: Regular, 1/2 inch, or Type X, 5/8 inch thick. See Drawings for locations.
 - 4. Size: 48 by 96 inches, or 48 by 108 inches, or 48 by 120 inches for vertical installation.

MODIFY - Section 06 1000 SHEATHING Section 2.3 as shown below:

REMOVE:

- A. Plywood Sheathing: DOC PS 1, Exterior sheathing.
 - 1. Nominal Thickness: Not less than 1/2 inch.

ADD:

- 2.3 PARAPET SHEATHING
 - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - a. G-P Gypsum Corporation.
 - b. Or approved equal.
 - 2. Basis of Design: DensDeck®
 - a. Type and Thickness: Regular, 1/2 inch thick.
 - b. Edge and End Configuration: Square.
 - c. Size: 48 by 96 inches.

SHEETS

ATTACHMENTS

END OF ADDENDUM NO. 2